

Appendix A.3 – BRUKL Reports (Be Lean)

Project name

Block F - Office - Be Clean

As designed

Date: Wed Aug 09 12:17:54 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Foundation area [m²]: 24.15

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 12.4 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 10.57 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 73.19 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 69.68 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | 09000001:Surf[2] |
| Floors | 0.18 | 0.1 | 0.1 | 09000001:Surf[3] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | 09000001:Surf[0] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors^ | 1.6 | 0.8 | 0.8 | 09000001:Surf[1] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
 U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
 U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-----------------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| BF-04 Marketing Suite | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Closing room | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Kitchennette | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC ACC. | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Cafe Offering | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| BF04 Marketing Suite | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Shower | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Shower lobby | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Resident Offices | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|----------------|-------------------|----------------------|-----------------------------------|
| Zone name | Standard value | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| BF-04 Marketing Suite | 125 | - | - | - |
| Closing room | 125 | - | - | - |
| WC | 125 | - | - | - |
| Kitchennette | 125 | - | - | - |
| WC ACC. | 125 | - | - | - |
| WC | 125 | - | - | - |
| Cafe Offering | 125 | - | - | - |
| BF04 Marketing Suite | 125 | - | - | - |
| Shower | 125 | - | - | - |
| Shower lobby | 125 | - | - | - |
| Resident Offices | 125 | - | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------------|--------------------------------|-----------------------|
| BF-04 Marketing Suite | NO (-14%) | NO |
| Closing room | N/A | N/A |
| WC | N/A | N/A |
| Kitchennette | N/A | N/A |
| WC ACC. | N/A | N/A |
| WC | N/A | N/A |
| Cafe Offering | YES (+32.7%) | NO |
| BF04 Marketing Suite | NO (-2.7%) | NO |
| Shower | N/A | N/A |
| Shower lobby | N/A | N/A |
| Resident Offices | NO (-36.1%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 289.8 | 289.8 | | Retail/Financial and Professional Services |
| External area [m ²] | 490.3 | 490.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 100 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 147.81 | 187.97 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.3 | 0.38 | | Hotels |
| Alpha value* [%] | 9.99 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 9.63 | 18.16 |
| Cooling | 7.04 | 2.1 |
| Auxiliary | 9.78 | 11.58 |
| Lighting | 3.88 | 8.47 |
| Hot water | 19.01 | 24.4 |
| Equipment* | 35.73 | 35.73 |
| TOTAL** | 49.33 | 64.71 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 2.74 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 113.41 | 94.12 |
| Primary energy [kWh _{PE} /m ²] | 69.68 | 73.19 |
| Total emissions [kg/m ²] | 10.57 | 12.4 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 31.1 | 82.3 | 9.6 | 7 | 9.8 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 59.2 | 34.9 | 18.2 | 2.1 | 8.9 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block F - Resi Areas - Be Clean As designed

Date: Fri Aug 04 17:16:56 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name
Telephone number: Phone
Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache
Calculation engine version: 7.0.22
Interface to calculation engine: IES Virtual Environment
Interface to calculation engine version: 7.0.22
BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 5.81

The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 7.74 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 5.4 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 60.88 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 50.12 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|---|
| Walls* | 0.26 | 0.14 | 0.14 | 0900000E:Surf[1] |
| Floors | 0.18 | 0.1 | 0.1 | 0900000E:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | - | - | No windows, galzed doors, or roof windows in building |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors^ | 1.6 | 1 | 1 | 0900000E:Surf[3] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|---------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| Circulation | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Parcel | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Security room | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

General lighting and display lighting

| Zone name | General luminaire | Display light source | |
|---------------|-------------------|----------------------|-----------------------------------|
| | | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 0.3 |
| Circulation | | 125 | - |
| Parcel | | 125 | - |
| Security room | | 125 | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|---------------|--------------------------------|-----------------------|
| Circulation | N/A | N/A |
| Parcel | N/A | N/A |
| Security room | N/A | N/A |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 69.7 | 69.7 | | Retail/Financial and Professional Services |
| External area [m ²] | 118.3 | 118.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 18.52 | 41.81 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.16 | 0.35 | 100 | Hotels |
| Alpha value* [%] | 10 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 4.67 | 15.17 |
| Cooling | 3.9 | 3.25 |
| Auxiliary | 11.65 | 16.45 |
| Lighting | 12.62 | 12.88 |
| Hot water | 1.1 | 1.07 |
| Equipment* | 39.86 | 39.86 |
| TOTAL** | 33.94 | 48.83 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 2.74 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 60.62 | 103.72 |
| Primary energy [kWh _{PE} /m ²] | 50.12 | 60.88 |
| Total emissions [kg/m ²] | 5.4 | 7.74 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 15.1 | 45.6 | 4.7 | 3.9 | 11.7 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 49.5 | 54.3 | 15.2 | 3.3 | 16.4 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block F - Retail - Be Clean

As designed

Date: Wed Aug 09 13:37:28 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 16.1The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 7.81 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 6.86 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 58.21 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 57.44 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | 09000000:Surf[2] |
| Floors | 0.18 | 0.1 | 0.1 | 09000000:Surf[3] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | 09000000:Surf[0] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | 09000000:Surf[1] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check.

*** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| BF02 Retail | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| BF01 Retail | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

General lighting and display lighting

| Zone name | General luminaire | Display light source | |
|-------------|-------------------|----------------------|-----------------------------------|
| | | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 |
| BF02 Retail | | 125 | 100 |
| BF01 Retail | | 125 | 100 |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------|--------------------------------|-----------------------|
| BF02 Retail | YES (+6.6%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------|--------------------------------|-----------------------|
| BF01 Retail | NO (-10.2%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

| | Actual | Notional |
|---|--------|----------|
| Floor area [m ²] | 193.2 | 193.2 |
| External area [m ²] | 354.3 | 354.3 |
| Weather | LON | LON |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 |
| Average conductance [W/K] | 117.8 | 145.75 |
| Average U-value [W/m ² K] | 0.33 | 0.41 |
| Alpha value* [%] | 9.99 | 10 |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

| % Area | Building Type |
|--------|---|
| 100 | Retail/Financial and Professional Services |
| | Restaurants and Cafes/Drinking Establishments/Takeaways |
| | Offices and Workshop Businesses |
| | General Industrial and Special Industrial Groups |
| | Storage or Distribution |
| | Hotels |
| | Residential Institutions: Hospitals and Care Homes |
| | Residential Institutions: Residential Schools |
| | Residential Institutions: Universities and Colleges |
| | Secure Residential Institutions |
| | Residential Spaces |
| | Non-residential Institutions: Community/Day Centre |
| | Non-residential Institutions: Libraries, Museums, and Galleries |
| | Non-residential Institutions: Education |
| | Non-residential Institutions: Primary Health Care Building |
| | Non-residential Institutions: Crown and County Courts |
| | General Assembly and Leisure, Night Clubs, and Theatres |
| | Others: Passenger Terminals |
| | Others: Emergency Services |
| | Others: Miscellaneous 24hr Activities |
| | Others: Car Parks 24 hrs |
| | Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 9.41 | 16.55 |
| Cooling | 8.58 | 2.36 |
| Auxiliary | 13.44 | 12.26 |
| Lighting | 6.13 | 14.5 |
| Hot water | 1.93 | 1.87 |
| Equipment* | 20.25 | 20.25 |
| TOTAL** | 39.49 | 47.55 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|----------|-------------|
| Photovoltaic systems | 0 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>0</i> | <i>2.74</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 130.74 | 93.29 |
| Primary energy [kWh _{PE} /m ²] | 57.44 | 58.21 |
| Total emissions [kg/m ²] | 6.86 | 7.81 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 30.4 | 100.4 | 9.4 | 8.6 | 13.4 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 53.9 | 39.4 | 16.5 | 2.4 | 12.3 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block H - Resi areas - Be Clean

As built

Date: Thu Aug 10 08:35:11 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 21.03The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 8.97 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 6.98 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 66.23 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 62.03 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | BL000007:Surf[2] |
| Floors | 0.18 | 0.1 | 0.1 | BL000007:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | BL000007:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | BL000007:Surf[5] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- system

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|--------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| LOBBY | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| CORRIDOR | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| LOBBY | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| CORRIDOR | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| LOBBY & POST | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| LOBBY & POST | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| LOBBY | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| LOBBY | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

General lighting and display lighting

| Zone name | General luminaire | Display light source | |
|-----------|-------------------|----------------------|-----------------------------------|
| | | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 0.3 |
| LOBBY | | 125 | - |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|----------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| CORRIDOR | | 125 | - | - |
| LOBBY | | 125 | - | - |
| CORRIDOR | | 125 | - | - |
| LOBBY & POST | | 125 | - | - |
| LOBBY & POST | | 125 | - | - |
| LOBBY | | 125 | - | - |
| LOBBY | | 125 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|--------------|--------------------------------|-----------------------|
| LOBBY | NO (-44.5%) | NO |
| CORRIDOR | N/A | N/A |
| LOBBY | NO (-12.7%) | NO |
| CORRIDOR | N/A | N/A |
| LOBBY & POST | YES (+4.5%) | NO |
| LOBBY & POST | YES (+7.5%) | NO |
| LOBBY | N/A | N/A |
| LOBBY | N/A | N/A |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

| | Actual | Notional |
|---|--------|----------|
| Floor area [m ²] | 168.3 | 168.3 |
| External area [m ²] | 286.9 | 286.9 |
| Weather | LON | LON |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 |
| Average conductance [W/K] | 82.95 | 110.41 |
| Average U-value [W/m ² K] | 0.29 | 0.38 |
| Alpha value* [%] | 9.99 | 10 |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

| % Area | Building Type |
|------------|---|
| | Retail/Financial and Professional Services |
| | Restaurants and Cafes/Drinking Establishments/Takeaways |
| | Offices and Workshop Businesses |
| | General Industrial and Special Industrial Groups |
| | Storage or Distribution |
| 100 | Hotels |
| | Residential Institutions: Hospitals and Care Homes |
| | Residential Institutions: Residential Schools |
| | Residential Institutions: Universities and Colleges |
| | Secure Residential Institutions |
| | Residential Spaces |
| | Non-residential Institutions: Community/Day Centre |
| | Non-residential Institutions: Libraries, Museums, and Galleries |
| | Non-residential Institutions: Education |
| | Non-residential Institutions: Primary Health Care Building |
| | Non-residential Institutions: Crown and County Courts |
| | General Assembly and Leisure, Night Clubs, and Theatres |
| | Others: Passenger Terminals |
| | Others: Emergency Services |
| | Others: Miscellaneous 24hr Activities |
| | Others: Car Parks 24 hrs |
| | Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 9.26 | 19.52 |
| Cooling | 7.15 | 2.64 |
| Auxiliary | 17.79 | 16.23 |
| Lighting | 8.07 | 12.31 |
| Hot water | 0 | 0 |
| Equipment* | 48.62 | 48.62 |
| TOTAL** | 42.27 | 50.71 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 4.11 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 4.11 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 113.31 | 107.69 |
| Primary energy [kWh _{PE} /m ²] | 62.03 | 66.23 |
| Total emissions [kg/m ²] | 6.98 | 8.97 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 29.8 | 83.5 | 9.3 | 7.1 | 17.8 | 0.89 | 3.24 | 1 | 3.92 |
| Notional | 63.6 | 44.1 | 19.5 | 2.6 | 16.2 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block H - retail - Be Clean

As built

Date: Wed Aug 09 14:07:47 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 101.2The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 9.14 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 6.86 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 67.15 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 57.91 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | BL000003:Surf[5] |
| Floors | 0.18 | 0.1 | 0.1 | BL000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | BL000003:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | BL000003:Surf[3] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- system

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-----------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| RETAIL BH3 - 01 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 02 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 03 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 01 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 02 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 03 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 05 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 06 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 06 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 05 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-----------------|-------------------|-----|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | ID of system type | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| RETAIL BH2 - 01 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 03 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 02 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BOH | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC & SHOWER | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|----------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| RETAIL BH3 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 02 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 02 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 05 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 06 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 06 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 05 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 02 | | 125 | 100 | 1.5 |
| RETAIL BOH | | 125 | - | - |
| WC & SHOWER | | 125 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| RETAIL BH3 - 01 | NO (-62%) | NO |
| RETAIL BH3 - 02 | NO (-52.4%) | NO |
| RETAIL BH3 - 03 | NO (-44.3%) | NO |
| RETAIL BH3 - 04 | NO (-47.5%) | NO |
| RETAIL BH2 - 01 | NO (-43.9%) | NO |
| RETAIL BH2 - 02 | NO (-14.3%) | NO |
| RETAIL BH2 - 03 | NO (-23.2%) | NO |
| RETAIL BH2 - 04 | NO (-48.4%) | NO |
| RETAIL BH2 - 05 | YES (+14.3%) | NO |
| RETAIL BH2 - 06 | NO (-31.9%) | NO |
| RETAIL BH2 - 06 | NO (-31.9%) | NO |
| RETAIL BH2 - 05 | NO (-9.6%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| RETAIL BH2 - 04 | NO (-37.3%) | NO |
| RETAIL BH2 - 01 | NO (-43.9%) | NO |
| RETAIL BH2 - 03 | NO (-25.7%) | NO |
| RETAIL BH2 - 02 | NO (-14.6%) | NO |
| RETAIL BOH | NO (-52.1%) | NO |
| WC & SHOWER | N/A | N/A |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 809.6 | 809.6 | 100 | Retail/Financial and Professional Services |
| External area [m ²] | 1526.3 | 1526.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 431.71 | 620.95 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.28 | 0.41 | | Hotels |
| Alpha value* [%] | 9.99 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 8.84 | 18.04 |
| Cooling | 6.89 | 2.73 |
| Auxiliary | 12.49 | 12.94 |
| Lighting | 9.4 | 15.63 |
| Hot water | 2.04 | 1.99 |
| Equipment* | 28.87 | 28.87 |
| TOTAL** | 39.66 | 51.32 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|----------|-------------|
| Photovoltaic systems | 0 | 4.11 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>0</i> | <i>4.11</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 108.89 | 104.27 |
| Primary energy [kWh _{PE} /m ²] | 57.91 | 67.15 |
| Total emissions [kg/m ²] | 6.86 | 9.14 |

HVAC Systems Performance

| System Type | Heat dem MJ/m ² | Cool dem MJ/m ² | Heat con kWh/m ² | Cool con kWh/m ² | Aux con kWh/m ² | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 28.5 | 80.4 | 8.8 | 6.9 | 12.5 | 0.89 | 3.24 | 1 | 3.92 |
| Notional | 58.8 | 45.5 | 18 | 2.7 | 12.9 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|--------------------------------|---|
| Heat dem [MJ/m ²] | = Heating energy demand |
| Cool dem [MJ/m ²] | = Cooling energy demand |
| Heat con [kWh/m ²] | = Heating energy consumption |
| Cool con [kWh/m ²] | = Cooling energy consumption |
| Aux con [kWh/m ²] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block I - Resi Areas - Be Lean

As built

Date: Fri Aug 04 17:53:49 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 9.7The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 12.67 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 10.55 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 137.2 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 114.26 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | GF000000:Surf[3] |
| Floors | 0.18 | 0.1 | 0.1 | GF000000:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 1.4 | 1.4 | GF000000:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | - | - | No personnel doors in building |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- Heat Pump (no cooling) (Lean)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|------------------|---------------|
| This system | 2.64 | - | 0.2 | 1.1 | 0.85 |
| Standard value | 2.5* | N/A | N/A | 1.9 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system

YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

1- Heat Pump (Hot water Lean)

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 2.86 | - |
| Standard value | 1 | N/A |

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

| Zone name | General lighting and display lighting | | General luminaire | | Display light source | |
|--------------|---------------------------------------|-----------------|-------------------|-----------------------------------|----------------------|-----------------------------------|
| | Standard value | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] | Efficacy [lm/W] | Power density [W/m ²] |
| Lobby | | 125 | - | - | - | - |
| Parcel | | 125 | - | - | - | - |
| Resi Amenity | | 125 | 120 | 1.25 | | |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|--------------|--------------------------------|-----------------------|
| Resi Amenity | NO (-24.1%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 106.7 | 106.7 | | Retail/Financial and Professional Services |
| External area [m ²] | 213.3 | 213.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 71 | 82.93 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.33 | 0.39 | 100 | Hotels |
| Alpha value* [%] | 10 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 3.81 | 4.95 |
| Cooling | 0 | 0 |
| Auxiliary | 11.81 | 19.81 |
| Lighting | 11.52 | 15.43 |
| Hot water | 48.13 | 52.48 |
| Equipment* | 62.2 | 62.2 |
| TOTAL** | 75.27 | 92.68 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 38.48 | 49.56 |
| Primary energy [kWh _{PE} /m ²] | 114.26 | 137.2 |
| Total emissions [kg/m ²] | 10.55 | 12.67 |

HVAC Systems Performance

| System Type | Heat dem MJ/m ² | Cool dem MJ/m ² | Heat con kWh/m ² | Cool con kWh/m ² | Aux con kWh/m ² | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|---------------|---------------|------------------|------------------|
| [ST] Central heating using air distribution, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 38.5 | 0 | 3.8 | 0 | 11.8 | 2.81 | 0 | 2.64 | 0 |
| Notional | 49.6 | 0 | 5 | 0 | 11.8 | 2.78 | 0 | ---- | ---- |

Key to terms

| | |
|--------------------------------|---|
| Heat dem [MJ/m ²] | = Heating energy demand |
| Cool dem [MJ/m ²] | = Cooling energy demand |
| Heat con [kWh/m ²] | = Heating energy consumption |
| Cool con [kWh/m ²] | = Cooling energy consumption |
| Aux con [kWh/m ²] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Appendix A.4 - BRUKL Reports (Be Green)

Project name

Block F - Office - Be Green

As designed

Date: Wed Aug 09 12:19:55 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 24.15The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 12.4 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 9.26 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 73.19 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 54.85 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | 09000001:Surf[2] |
| Floors | 0.18 | 0.1 | 0.1 | 09000001:Surf[3] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | 09000001:Surf[0] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | 09000001:Surf[1] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-----------------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| BF-04 Marketing Suite | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Closing room | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Kitchennette | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC ACC. | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Cafe Offering | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| BF04 Marketing Suite | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Shower | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Shower lobby | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Resident Offices | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|----------------|-------------------|----------------------|-----------------------------------|
| Zone name | Standard value | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| BF-04 Marketing Suite | 125 | - | - | - |
| Closing room | 125 | - | - | - |
| WC | 125 | - | - | - |
| Kitchennette | 125 | - | - | - |
| WC ACC. | 125 | - | - | - |
| WC | 125 | - | - | - |
| Cafe Offering | 125 | - | - | - |
| BF04 Marketing Suite | 125 | - | - | - |
| Shower | 125 | - | - | - |
| Shower lobby | 125 | - | - | - |
| Resident Offices | 125 | - | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------------|--------------------------------|-----------------------|
| BF-04 Marketing Suite | NO (-14%) | NO |
| Closing room | N/A | N/A |
| WC | N/A | N/A |
| Kitchennette | N/A | N/A |
| WC ACC. | N/A | N/A |
| WC | N/A | N/A |
| Cafe Offering | YES (+32.7%) | NO |
| BF04 Marketing Suite | NO (-2.7%) | NO |
| Shower | N/A | N/A |
| Shower lobby | N/A | N/A |
| Resident Offices | NO (-36.1%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 289.8 | 289.8 | | Retail/Financial and Professional Services |
| External area [m ²] | 490.3 | 490.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | 100 | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 147.81 | 187.97 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.3 | 0.38 | | Hotels |
| Alpha value* [%] | 9.99 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 9.63 | 18.16 |
| Cooling | 7.04 | 2.1 |
| Auxiliary | 9.78 | 11.58 |
| Lighting | 3.88 | 8.47 |
| Hot water | 19.01 | 24.4 |
| Equipment* | 35.73 | 35.73 |
| TOTAL** | 49.33 | 64.71 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|--------------|-------------|
| Photovoltaic systems | 10.06 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>10.06</i> | <i>2.74</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 113.41 | 94.12 |
| Primary energy [kWh _{PE} /m ²] | 54.85 | 73.19 |
| Total emissions [kg/m ²] | 9.26 | 12.4 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 31.1 | 82.3 | 9.6 | 7 | 9.8 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 59.2 | 34.9 | 18.2 | 2.1 | 8.9 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block F - Resi Areas - Be Green

As designed

Date: Fri Aug 04 17:17:56 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 5.81The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 7.74 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 3.91 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 60.88 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 33.15 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|---|
| Walls* | 0.26 | 0.14 | 0.14 | 0900000E:Surf[1] |
| Floors | 0.18 | 0.1 | 0.1 | 0900000E:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | - | - | No windows, galzed doors, or roof windows in building |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 1 | 1 | 0900000E:Surf[3] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|---------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| Circulation | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Parcel | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| Security room | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

General lighting and display lighting

| Zone name | General luminaire | Display light source | |
|---------------|-------------------|----------------------|-----------------------------------|
| | | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 0.3 |
| Circulation | | 125 | - |
| Parcel | | 125 | - |
| Security room | | 125 | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|---------------|--------------------------------|-----------------------|
| Circulation | N/A | N/A |
| Parcel | N/A | N/A |
| Security room | N/A | N/A |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 69.7 | 69.7 | | Retail/Financial and Professional Services |
| External area [m ²] | 118.3 | 118.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 18.52 | 41.81 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.16 | 0.35 | 100 | Hotels |
| Alpha value* [%] | 10 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 4.67 | 15.17 |
| Cooling | 3.9 | 3.25 |
| Auxiliary | 11.65 | 16.45 |
| Lighting | 12.62 | 12.88 |
| Hot water | 1.1 | 1.07 |
| Equipment* | 39.86 | 39.86 |
| TOTAL** | 33.94 | 48.83 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|-------------|-------------|
| Photovoltaic systems | 11.5 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>11.5</i> | <i>2.74</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 60.62 | 103.72 |
| Primary energy [kWh _{PE} /m ²] | 33.15 | 60.88 |
| Total emissions [kg/m ²] | 3.91 | 7.74 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 15.1 | 45.6 | 4.7 | 3.9 | 11.7 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 49.5 | 54.3 | 15.2 | 3.3 | 16.4 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block F - Retail - Be Green

As designed

Date: Wed Aug 09 13:38:48 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 16.1The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 7.81 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 5.56 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 58.21 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 42.63 |
| Do the building's emission and primary energy rates exceed the targets? | BER =< TER BPER =< TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | 09000000:Surf[2] |
| Floors | 0.18 | 0.1 | 0.1 | 09000000:Surf[3] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | 09000000:Surf[0] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | 09000000:Surf[1] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check.

*** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- System HN

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| BF02 Retail | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| BF01 Retail | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

General lighting and display lighting

| Zone name | General luminaire | Display light source | |
|-------------|-------------------|----------------------|-----------------------------------|
| | | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 |
| BF02 Retail | | 125 | 100 |
| BF01 Retail | | 125 | 100 |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------|--------------------------------|-----------------------|
| BF02 Retail | YES (+6.6%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------|--------------------------------|-----------------------|
| BF01 Retail | NO (-10.2%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

| | Actual | Notional |
|---|--------|----------|
| Floor area [m ²] | 193.2 | 193.2 |
| External area [m ²] | 354.3 | 354.3 |
| Weather | LON | LON |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 |
| Average conductance [W/K] | 117.8 | 145.75 |
| Average U-value [W/m ² K] | 0.33 | 0.41 |
| Alpha value* [%] | 9.99 | 10 |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

| % Area | Building Type |
|--------|---|
| 100 | Retail/Financial and Professional Services |
| | Restaurants and Cafes/Drinking Establishments/Takeaways |
| | Offices and Workshop Businesses |
| | General Industrial and Special Industrial Groups |
| | Storage or Distribution |
| | Hotels |
| | Residential Institutions: Hospitals and Care Homes |
| | Residential Institutions: Residential Schools |
| | Residential Institutions: Universities and Colleges |
| | Secure Residential Institutions |
| | Residential Spaces |
| | Non-residential Institutions: Community/Day Centre |
| | Non-residential Institutions: Libraries, Museums, and Galleries |
| | Non-residential Institutions: Education |
| | Non-residential Institutions: Primary Health Care Building |
| | Non-residential Institutions: Crown and County Courts |
| | General Assembly and Leisure, Night Clubs, and Theatres |
| | Others: Passenger Terminals |
| | Others: Emergency Services |
| | Others: Miscellaneous 24hr Activities |
| | Others: Car Parks 24 hrs |
| | Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 9.41 | 16.55 |
| Cooling | 8.58 | 2.36 |
| Auxiliary | 13.44 | 12.26 |
| Lighting | 6.13 | 14.5 |
| Hot water | 1.93 | 1.87 |
| Equipment* | 20.25 | 20.25 |
| TOTAL** | 39.49 | 47.55 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|--------------|-------------|
| Photovoltaic systems | 10.04 | 2.74 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>10.04</i> | <i>2.74</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 130.74 | 93.29 |
| Primary energy [kWh _{PE} /m ²] | 42.63 | 58.21 |
| Total emissions [kg/m ²] | 5.56 | 7.81 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 30.4 | 100.4 | 9.4 | 8.6 | 13.4 | 0.9 | 3.25 | 1 | 3.92 |
| Notional | 53.9 | 39.4 | 16.5 | 2.4 | 12.3 | 0.91 | 4.63 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |

Project name

Block H - retail - Be Green

As built

Date: Wed Aug 09 14:04:20 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 101.2The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 9.14 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 5.97 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 67.15 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 47.77 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | BL000003:Surf[5] |
| Floors | 0.18 | 0.1 | 0.1 | BL000003:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 0.8 | 0.8 | BL000003:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors [^] | 1.6 | 0.8 | 0.8 | BL000003:Surf[3] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- system

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|----------------|---------------|
| This system | 1 | 3.92 | 0 | 1.1 | 0.85 |
| Standard value | N/A | N/A | N/A | 2 [^] | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system YES

[^] Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

"No HWS in project, or hot water is provided by HVAC system"

1- District heating network

| | Emission factor [kgCO ₂ /kWh] | Primary energy factor [kWh _{PE} /kWh] |
|----------------|--|--|
| This building | 0.273 | 1.356 |
| Standard value | 0.35 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | ID of system type | SFP [W/(l/s)] | | | | | | | | | HR efficiency | |
|-----------------|-------------------|---------------|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| RETAIL BH3 - 01 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 02 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 03 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH3 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 01 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 02 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 03 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 05 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 06 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 06 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 05 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 04 | | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-----------------|-------------------|-----|-----|-----|-----|---|-----|-----|-----|---|---------------|----------|
| | ID of system type | A | B | C | D | E | F | G | H | I | Zone | Standard |
| | Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | |
| RETAIL BH2 - 01 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 03 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BH2 - 02 | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| RETAIL BOH | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |
| WC & SHOWER | - | - | - | - | - | - | - | - | 0.3 | - | - | N/A |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|----------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| RETAIL BH3 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 02 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH3 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 02 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 05 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 06 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 06 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 05 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 04 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 01 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 03 | | 125 | 100 | 1.5 |
| RETAIL BH2 - 02 | | 125 | 100 | 1.5 |
| RETAIL BOH | | 125 | - | - |
| WC & SHOWER | | 125 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| RETAIL BH3 - 01 | NO (-62%) | NO |
| RETAIL BH3 - 02 | NO (-52.4%) | NO |
| RETAIL BH3 - 03 | NO (-44.3%) | NO |
| RETAIL BH3 - 04 | NO (-47.5%) | NO |
| RETAIL BH2 - 01 | NO (-43.9%) | NO |
| RETAIL BH2 - 02 | NO (-14.3%) | NO |
| RETAIL BH2 - 03 | NO (-23.2%) | NO |
| RETAIL BH2 - 04 | NO (-48.4%) | NO |
| RETAIL BH2 - 05 | YES (+14.3%) | NO |
| RETAIL BH2 - 06 | NO (-31.9%) | NO |
| RETAIL BH2 - 06 | NO (-31.9%) | NO |
| RETAIL BH2 - 05 | NO (-9.6%) | NO |

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-----------------|--------------------------------|-----------------------|
| RETAIL BH2 - 04 | NO (-37.3%) | NO |
| RETAIL BH2 - 01 | NO (-43.9%) | NO |
| RETAIL BH2 - 03 | NO (-25.7%) | NO |
| RETAIL BH2 - 02 | NO (-14.6%) | NO |
| RETAIL BOH | NO (-52.1%) | NO |
| WC & SHOWER | N/A | N/A |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|-----|
| Were alternative energy systems considered and analysed as part of the design process? | YES |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | YES |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 809.6 | 809.6 | 100 | Retail/Financial and Professional Services |
| External area [m ²] | 1526.3 | 1526.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 431.71 | 620.95 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.28 | 0.41 | | Hotels |
| Alpha value* [%] | 9.99 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 8.84 | 18.04 |
| Cooling | 6.89 | 2.73 |
| Auxiliary | 12.49 | 12.94 |
| Lighting | 9.4 | 15.63 |
| Hot water | 2.04 | 1.99 |
| Equipment* | 28.87 | 28.87 |
| TOTAL** | 39.66 | 51.32 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|-------------|-------------|
| Photovoltaic systems | 6.87 | 4.11 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>6.87</i> | <i>4.11</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 108.89 | 104.27 |
| Primary energy [kWh _{PE} /m ²] | 47.77 | 67.15 |
| Total emissions [kg/m ²] | 5.97 | 9.14 |

HVAC Systems Performance

| System Type | Heat dem MJ/m ² | Cool dem MJ/m ² | Heat con kWh/m ² | Cool con kWh/m ² | Aux con kWh/m ² | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|---|-------------------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] District heating, [HFT] District Heating, [CFT] Electricity | | | | | | | | | |
| Actual | 28.5 | 80.4 | 8.8 | 6.9 | 12.5 | 0.89 | 3.24 | 1 | 3.92 |
| Notional | 58.8 | 45.5 | 18 | 2.7 | 12.9 | 0.91 | 4.63 | ---- | ---- |

Key to terms

- Heat dem [MJ/m²] = Heating energy demand
- Cool dem [MJ/m²] = Cooling energy demand
- Heat con [kWh/m²] = Heating energy consumption
- Cool con [kWh/m²] = Cooling energy consumption
- Aux con [kWh/m²] = Auxiliary energy consumption
- Heat SSEFF = Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
- Cool SSEER = Cooling system seasonal energy efficiency ratio
- Heat gen SSEFF = Heating generator seasonal efficiency
- Cool gen SSEER = Cooling generator seasonal energy efficiency ratio
- ST = System type
- HS = Heat source
- HFT = Heating fuel type
- CFT = Cooling fuel type

Project name

Block I - Resi Areas - Be Green

As built

Date: Fri Aug 04 17:55:56 2023

Administrative information

Building Details

Address: Address 1, City, Postcode

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.22

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.22

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 9.7The CO₂ emission and primary energy rates of the building must not exceed the targets

| | |
|--|---------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² :annum | 12.67 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² :annum | 9.94 |
| Target primary energy rate (TPER), kWh _{PE} /m ² :annum | 137.2 |
| Building primary energy rate (BPER), kWh _{PE} /m ² :annum | 107.73 |
| Do the building's emission and primary energy rates exceed the targets? | BER <= TER BPER <= TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 0.14 | 0.14 | GF000000:Surf[3] |
| Floors | 0.18 | 0.1 | 0.1 | GF000000:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | - | - | No flat roofs in building |
| Windows** and roof windows | 1.6 | 1.4 | 1.4 | GF000000:Surf[1] |
| Rooflights*** | 2.2 | - | - | No roof lights in building |
| Personnel doors^ | 1.6 | - | - | No personnel doors in building |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]
U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]
U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.
** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.
^ For fire doors, limiting U-value is 1.8 W/m²K
NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 2.5 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|--|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | YES |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- Heat Pump (no cooling)

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|----------------|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 3.1 | - | 0.2 | 1.1 | 0.85 |
| Standard value | 2.5* | N/A | N/A | 1.9^ | N/A |

Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system

YES

* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.

^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

1- Heat Pump (Hot water)

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|----------------|--------------------------|---|
| This building | 3.1 | - |
| Standard value | 1 | N/A |

"No zones in project where local mechanical ventilation, exhaust, or terminal unit is applicable"

| Zone name | General lighting and display lighting | | General luminaire | | Display light source | |
|--------------|---------------------------------------|-----------------|-------------------|-----------------------------------|----------------------|-----------------------------------|
| | Standard value | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] | Efficacy [lm/W] | Power density [W/m ²] |
| Lobby | | 125 | - | - | - | - |
| Parcel | | 125 | - | - | - | - |
| Resi Amenity | | 125 | 120 | 1.25 | | |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|--------------|--------------------------------|-----------------------|
| Resi Amenity | NO (-24.1%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|--|----|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

| Building Global Parameters | | | Building Use | |
|---|--------|----------|--------------|---|
| | Actual | Notional | % Area | Building Type |
| Floor area [m ²] | 106.7 | 106.7 | | Retail/Financial and Professional Services |
| External area [m ²] | 213.3 | 213.3 | | Restaurants and Cafes/Drinking Establishments/Takeaways |
| Weather | LON | LON | | Offices and Workshop Businesses |
| Infiltration [m ³ /hm ² @ 50Pa] | 3 | 3 | | General Industrial and Special Industrial Groups |
| Average conductance [W/K] | 71 | 82.93 | | Storage or Distribution |
| Average U-value [W/m ² K] | 0.33 | 0.39 | 100 | Hotels |
| Alpha value* [%] | 10 | 10 | | Residential Institutions: Hospitals and Care Homes |
| | | | | Residential Institutions: Residential Schools |
| | | | | Residential Institutions: Universities and Colleges |
| | | | | Secure Residential Institutions |
| | | | | Residential Spaces |
| | | | | Non-residential Institutions: Community/Day Centre |
| | | | | Non-residential Institutions: Libraries, Museums, and Galleries |
| | | | | Non-residential Institutions: Education |
| | | | | Non-residential Institutions: Primary Health Care Building |
| | | | | Non-residential Institutions: Crown and County Courts |
| | | | | General Assembly and Leisure, Night Clubs, and Theatres |
| | | | | Others: Passenger Terminals |
| | | | | Others: Emergency Services |
| | | | | Others: Miscellaneous 24hr Activities |
| | | | | Others: Car Parks 24 hrs |
| | | | | Others: Stand Alone Utility Block |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|--------------|
| Heating | 3.24 | 4.95 |
| Cooling | 0 | 0 |
| Auxiliary | 11.81 | 19.81 |
| Lighting | 11.52 | 15.43 |
| Hot water | 44.4 | 52.48 |
| Equipment* | 62.2 | 62.2 |
| TOTAL** | 70.98 | 92.68 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.
 ** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|-----------------------|--------|----------|
| Photovoltaic systems | 0 | 0 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| Displaced electricity | 0 | 0 |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 38.48 | 49.56 |
| Primary energy [kWh _{PE} /m ²] | 107.73 | 137.2 |
| Total emissions [kg/m ²] | 9.94 | 12.67 |

HVAC Systems Performance

| System Type | Heat dem MJ/m ² | Cool dem MJ/m ² | Heat con kWh/m ² | Cool con kWh/m ² | Aux con kWh/m ² | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------------------|-------------------------------|--------------------------------|--------------------------------|-------------------------------|---------------|---------------|------------------|------------------|
| [ST] Central heating using air distribution, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 38.5 | 0 | 3.2 | 0 | 11.8 | 3.3 | 0 | 3.1 | 0 |
| Notional | 49.6 | 0 | 5 | 0 | 11.8 | 2.78 | 0 | ---- | ---- |

Key to terms

| | |
|--------------------------------|---|
| Heat dem [MJ/m ²] | = Heating energy demand |
| Cool dem [MJ/m ²] | = Cooling energy demand |
| Heat con [kWh/m ²] | = Heating energy consumption |
| Cool con [kWh/m ²] | = Cooling energy consumption |
| Aux con [kWh/m ²] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |



ABERFELDY VILLAGE MASTERPLAN